

The below table describes locations of known or presumed asbestos containing building materials. The table is intended to provide general awareness information to the University community to avoid accidental disturbance of asbestos containing materials. This document should not be relied upon for maintenance, renovation or demolition activities. Additional asbestos containing materials may exist in in-accessible locations, such as above fixed ceilings and inside wall cavities. If you have any questions or concerns regarding asbestos containing materials please contact the Occupational Safety & Environmental Health Department (OSEH) at 734-647-1142 / OSEHAsbestos@umich.edu or you may refer to the Asbestos Management Program Guideline found on the OSEH website (www.oseh.umich.edu).

Building Name	Material Description	Location*
Kellogg Institute Building (Excludes the Dental School)	Ceiling Tile (Presumed)	GL01, 1L01
	Duct Insulation	Attic Space
	Electrical Wire for Stage Lighting	3052
	Fire Doors (Presumed)	Throughout Building
	Floor Tile	Throughout Building
	Floor Tile Mastic	Throughout Building
	Fume Hood Liner	G008
	Lab Table Top	G008, 507A, 1057, 2504, 2515, 2522
	Pipe Insulation (Straights)	Throughout Building
	Pipe Insulation (Fittings)	Throughout Building
	Tank Insulation	G000
	Vinyl Sheet Backing	G008

*Room numbers listed are as identified at the time of the survey