



BEFORE INITIATING HOT WORK, CAN THIS JOB BE AVOIDED? IS THERE A SAFER WAY?

This Hot Work Permit is required for any temporary operation involving open flames or producing heat and/or sparks. In occupied tenant space. This includes, but is not limited to: Brazing, Cutting, Grinding, Soldering, Thawing Pipe, Torch Applied Roofing and Welding.

**PART 1
 INSTRUCTIONS**

1. Fire safety Supervisor:
 - a. Verify precautions listed at right (or do not proceed with the work).
 - b. Complete and retain PART 1

HOT WORK BEING DONE BY:

- Employee
 Contractor _____

Date:	Job No.
-------	---------

Location/Building & Floor _____

Nature of Job _____

Name of Person Doing Hot Work _____

I verify the above location has been examined, the precautions checked on the Required Precautions Checklist have been taken to prevent fire, and permission is authorized for this work.

Signed: (Fire safety Supervisor) _____

Permit Expires:	Date	Time	AM PM
-----------------	------	------	----------

**NOTE EMERGENCY NOTIFICATION BELOW ON FORM.
 USE AS APPROPRIATE FOR YOUR FACILITY.**

Warning!

**HOT WORK IN PROGRESS
 WATCH FOR FIRE!**

IN CASE OF EMERGENCY:

CALL: _____

AT: _____

REQUIRED PRECAUTIONS CHECKLIST

- Available sprinklers, hose streams and extinguishers are in service/operable.
- Hot Work equipment in good repair.

Requirements within 35 ft. (11m) of work

- Flammable liquids, dust, lint and oily deposits removed.
- Explosive atmosphere in area eliminated.
- Floors swept clean.
- Combustible floors wet down, covered with damp sand or fire-resistive sheets.
- Remove other combustibles where possible. Otherwise protect with fire-resistive tarpaulins or metal shields.
- All wall and floor openings covered.
- Fire-resistive tarpaulins suspended beneath work.

Work on walls or ceilings

- Construction is noncombustible and without combustible covering or insulation.
- Combustibles on other side of walls moved away.

Work on enclosed equipment

- Enclosed equipment cleaned of all combustibles.
- Containers purged of flammable liquids/vapors.

Fire watch/Hot Work area monitoring

- Fire watch will be provided during and for 60 minutes after work, including any coffee or lunch breaks.
- Fire watch is supplied with suitable extinguishers, charged small hose.
- Fire watch is trained in use of this equipment and in sounding alarm.
- Fire watch may be required for adjoining areas, above, and below.
- Monitor Hot Work area for 3 hours after job is completed.

Other Precautions Taken

- _____