

The below table describes locations of known or presumed asbestos containing building materials. The table is intended to provide general awareness information to the University community to avoid accidental disturbance of asbestos containing materials. This document should not be relied upon for maintenance, renovation or demolition activities. Additional asbestos containing materials may exist in in-accessible locations, such as above fixed ceilings and inside wall cavities. If you have any questions or concerns regarding asbestos containing materials please contact the Occupational Safety & Environmental Health Department (OSEH) at 734-647-1142 / OSEHAsbestos@umich.edu or you may refer to the Asbestos Management Program Guideline found on the OSEH website (www.oseh.umich.edu).

Building Name	Material Description	Location*
Kraus Natural Science Building	Ceiling Tile Gluepod	3S40, 3S43, 3E41, 3140A, 3141, 3145
	Chalkboard (Presumed)	1083
	Cove Base	1023, 1078, 1260, 1270, 1272, 1272A, 2011, 2012, 3057, 3057A, 3057B, 3061, 4042
	Cove Base Mastic	1023, 1078, 1260, 1270, 1272, 1272A, 2011, 2012, 3057, 3057A, 3057B, 3061, 4042
	Fire Door (Presumed)	Throughout Building
	Floor Tile	Throughout Building
	Floor Tile Mastic	Throughout Building
	Fume Hood Liner	Throughout Building
	Fume Hood Cabinet Liner	Throughout Building
	Floor Sheeting	2031, 2031A, 2035, 2035A, 2035B, 2037, 2125B, 2125C, 1065, 1200, 3094
	Lab Sink Top	1065, 1200, 3094
	Lab Table Top	Throughout Building
	Pipe Insulation (Straights)	Throughout Building
	Pipe Insulation (Fittings)	Throughout Building
	Sink Undercoating	1078
	Window Shelf Sill	1065, 2081, 2092, 3003, 3057, 3061, 3086, 3095D, 4041, 4045, 4045B

*Room numbers listed are as identified at the time of the survey