

The below table describes locations of known or presumed asbestos containing building materials. The table is intended to provide general awareness information to the University community to avoid accidental disturbance of asbestos containing materials. This document should not be relied upon for maintenance, renovation or demolition activities. Additional asbestos containing materials may exist in in-accessible locations, such as above fixed ceilings and inside wall cavities. If you have any questions or concerns regarding asbestos containing materials please contact the Occupational Safety & Environmental Health Department (OSEH) at 734-647-1142 / [OSEHAsbestos@umich.edu](mailto:OSEHAsbestos@umich.edu) or you may refer to the Asbestos Management Program Guideline found on the OSEH website ([www.oseh.umich.edu](http://www.oseh.umich.edu)).

<b>Building Name</b>	<b>Material Description</b>	<b>Location*</b>
<b>Legal Research Library (excludes the Underground Library)</b>	Air Cell Board Inside Metal Partition Wall	709, 711
	Antique Door Glazing	3C08, 370
	Antique Window Glazing	Throughout Building
	Cove Base	Throughout Building
	Duct Insulation Inside Perimeter Wall	300
	Electrical Wire Insulation (Presumed)	811, 812, 815, 816, 1100
	Fire Door (Presumed)	Throughout Building
	Floor Covering and Mastic	970B
	Floor Tile	Throughout Building
	Pipe Insulation (Straights)	1C04, 1C05, 1V04, 105, 106A, 109A, 115, 115A, 115B, 118, 150E, 151, 154, 157, 160, 161, 190, 290, 490, 547W, 690, 735, 747M, 812, 815, 816, 831, 833, 835, 837, 847C, 992
	Pipe Insulation (Fittings)	1C04, 1C05, 105, 109A, 115, 115A, 115B, 118, 150E, 151, 154, 157, 161, 190, 290, 490, 547W, 690, 735, 815, 816, 831, 833, 835, 837, 992
	Radiator Backer Board	109, 300A-K, 310, 311, 312, 313, 321, 321A, 360, 361, 362, 363, 365, 365A, 371, 372, 3004, 921, 922
	Sink Undercoating	321A
	Transite Panel (Presumed)	1V03, 1V04
	Wall Caulk	190, 290, 490, 690
	Wall Mastic	735, 837
Window Caulk	Building Exterior	

\*Room numbers listed are as identified at the time of the survey