

The table below describes locations of known or presumed asbestos containing building materials. The table is intended to provide general awareness information to the University community to avoid accidental disturbance of asbestos containing materials. This document should not be relied upon for maintenance, renovation or demolition activities. Additional asbestos containing materials may exist in inaccessible locations, such as above fixed ceilings and inside wall cavities. These materials may have also been removed as part of maintenance or renovation activities in the years since they were identified by survey activities. Asbestos-containing material (ACM) means any material containing more than 1% asbestos. If you have any questions or concerns regarding asbestos containing materials please contact the Environment Health & Safety (EHS) office at 734-647-1143 or you may refer to the [Asbestos information page](#) found on the EHS website (www.ehs.umich.edu).

Building Name	Material Description	Location*
Buhr Building	Fire Doors (Presumed)	Throughout Building
	12" x 12" Ceiling Tile Gluepods	1000, 1001, 1004, 1005, 1015, 1503, 1001A, 1001B, 1001C, 1001D, 1001E, 1001F, 1001G, 1001I, 1001J, 1001L, 1002A, 1006A, 1017T, 1C01, 1C03, 1F01, 2500, 2501, 2502, 2503, 2511, 2512, 2514, 2518, 2522, 2524, 2526, 2530
	12" x 12" Floor Tile – Grey with Cream Streaks	1E14
	12" x 12" Floor Tile – White with Black Flecks	0101, 0107, 0110, 0120, 1L14, 1L14, 1S10, 1S23, 1S24, 305, 3210, 3212, 305B, 305C, 306A, 306D
	12" x 12" Floor Tile – Cream with White and Brown	1474, 1474A, 1510A, 1C50
	12" x 12" Floor Tile – Red and Brown with Tan Specks	2500, 2501, 2502, 2503, 2511, 2512, 2514, 2518, 2521, 2522, 2524, 2526, 2530, 2S40
	12" x 12" Floor Tile – Tan with Black Streaks	2500, 2501, 2502, 2503, 2511, 2512, 2514, 2518, 2521, 2522, 2524, 2526, 2530, 2S40
2' x 4' Ceiling Panel – Dots with Squiggles	1002A, 1006A, 1C03, CS07	

9" x 9" Floor Tile – Black with White Streaks	2012, 2012A
AirCell Pipe Insulation	1004, 1300, 1315, 1400, 1430, 1450, 1466, 1470, 1017T, 1300A, 1300C, 1315A, 1315B, 1M50
Fume Hood (Presumed)	3202
Mastic for 12" x 12" Floor Tile – White with Black	0101, 0107, 0110, 0120, 1L14, 1L14, 1S10, 1S23, 1S24, 305, 3210, 3212, 305B, 305C, 306A, 306D
Mud Fitting on Brown Paper Pipe Insulation	3210, 3210B
Mud Fitting on AirCell Pipe Insulation	1430, 1450, 1466, 1470, 1300A, 1300C, 1315A
Stair Tread – Light Green with Cream	2521
Transite Ceiling Panel	1010B
Vinyl Sheet Flooring – White Pebbles	201, 203, 301, 303, 403

*Room numbers listed are as identified at the time of the survey