

The table below describes locations of known or presumed asbestos containing building materials. The table is intended to provide general awareness information to the University community to avoid accidental disturbance of asbestos containing materials. This document should not be relied upon for maintenance, renovation or demolition activities. Additional asbestos containing materials may exist in inaccessible locations, such as above fixed ceilings and inside wall cavities. These materials may have also been removed as part of maintenance or renovation activities in the years since they were identified by survey activities. Asbestos-containing material (ACM) means any material containing more than 1% asbestos. If you have any questions or concerns regarding asbestos containing materials please contact the Environment Health & Safety (EHS) office at 734-647-1143 or you may refer to the [Asbestos information page](#) found on the EHS website ([www.ehs.umich.edu](http://www.ehs.umich.edu)).

Building Name	Material Description	Location*
<b>Shapiro Library</b>	Fire Doors (Presumed)  AirCell Pipe Insulation  9"x9" Floor Tile – Black with White Streaks  9"x9" Floor Tile – Gray with Black and White Streaks	Throughout Building  4108J, 3108J, 3026, 3030M, 3032J, 3036W, 2108J, 2030M, 2032A, 2036W, 1030M, 1032A, 1036W, 1108J, 1L11, B108J, B030M, B032A, B036W  3007P, 2007P, 2028E, 1028E, 1007P, B028, B007P  4186F, 4131F, 4097F, 4059F, 4033E, 4009F, 3028E

\*Room numbers listed are as identified at the time of the survey