



MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
AIR QUALITY DIVISION

**RENEWABLE OPERATING PERMIT
DEVIATION REPORT**

Authorized by 1994 P.A. 451, as amended. Failure to provide this information may result in civil and/or criminal penalties.

This form may be submitted in conjunction with the Renewable Operating Permit Report Certification form (EQP 5736) to report deviations from all general conditions and special conditions in the Renewable Operating Permit (ROP) for which deviations required to be reported by R 336.1213 (Rule 213) subrule (3)(c) have occurred. Additional information regarding the reports and documentation listed below must be kept on file for at least 5 years, as specified in Rule 213(3)(b)(ii), and be made available to the Department of Environment, Great Lakes, and Energy, Air Quality Division, upon request. Items 1 - 8 must be completed for all deviations being reported.

Source Name University of Michigan County Washtenaw

Source Address 1239 Kipke Drive City Ann Arbor

AQD Source ID (SRN) M0675 ROP No. ROP-M0675-2021b ROP Section No. _____

ROP Section Contact Steve O'Rielly Contact Phone No. 734-763-4642

Reporting Period (provide inclusive dates): From 1/1/2023 to 12/31/2023

Report Type: Annual Semi Annual Other (Describe) _____

1. Group or Source Wide ID FGEMERG-JJJJ	2. Condition No. V.2.b.ii	3. Date(s) of Occurrence 3/15/2023 and 4/19/2023	4. Previously reported ? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If Yes, Date 9/15/203	5. Duration of Deviation 30 minutes and 15 minutes
6. Method Used to Determine Compliance Status (if different from method specified in ROP) NA - engine was shut down immediately		7. Description of Deviation CSSB generator ran 30 minute weekly maintenance tests after engine failed 3-year emissions test.		
8. Reason for Deviation and Description of Corrective Action Taken During the 3-year emissions test, a turbo failed. The engine is set to run weekly by default therefore ran automatically. The engine was shutdown 15 mi after second automatic start. The weekly test was canceled until emissions test was completed. Test was completed on June 23, 2023.				

1. Group or Source Wide ID EUI0213-02	2. Condition No. VI.1	3. Date(s) of Occurrence 9/12/2023 - 9/15/2023	4. Previously reported ? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If Yes, Date 9/2023	5. Duration of Deviation 3 days
6. Method Used to Determine Compliance Status (if different from method specified in ROP) Daily stack observations; unit ran normal		7. Description of Deviation The entire building controls system had a communication issue. Affected areas of central and medical campus.		
8. Reason for Deviation and Description of Corrective Action Taken Control system failed and lost continuous burn data. Daily stack observations continued, specimen burned normal, and unit ran as normal. To ensure missed data doesn't go unnoticed for a period of time, weekly temperature logs changed to daily to ensure missed data doesn't get unnoticed.				

1. Group or Source Wide ID FGEMERG-JJJJ	2. Condition No. V.2.b.ii	3. Date(s) of Occurrence 10/28/2023	4. Previously reported ? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If Yes, Date 10/17/23	5. Duration of Deviation 1 day
6. Method Used to Determine Compliance Status (if different from method specified in ROP)		7. Description of Deviation South Quad emergency generator didn't meet 3-year test schedule due to failed engine.		
8. Reason for Deviation and Description of Corrective Action Taken South Quad emergency generator failed during 3-year emissions test. Unit was shut down and repairs underway. Set for emergency standby only. Test is rescheduled for early July 2024.				